

Certificate of Compliance

Certificate Number 20071116-E187894D
Report Reference E187894, 2002 September 25
Issue Date 2007 November 16

Page 1 of 1



Issued to: **Medc**
Colliery Rd, Pinxton, Nottingham
NG16 6JF England, United Kingdom


This is to certify that representative samples of **Visual Signal Devices**
Series FL4 for use in Class I, Division 1, Groups C and D;
Class I, Zone 1 AEx d IIB Hazardous Locations.
Class I, Zone 1 Ex d IIB Hazardous Locations.

Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 1638, Fourth Edition; UL 1203, Fourth Edition; UL 60079-0, Fourth Edition; UL 60079-1, Fifth Edition; CSA 22.2 No. 30:1986; CSA 22.2 No. 250.0-04; CSA E60079-0, 1998; CSA E60079-1, 2001.

Additional Information: Marking shall include the Listee's name or registered trademark, Device model designation and Ambient temperature range -55°C to 55°C.

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product

Issued by: *Russell L. Filip*
Russell L. Filip/Staff Engineer
Underwriters Laboratories Inc.

Reviewed by: *Paul T. Kelly*
Paul T. Kelly/Operations Manager
Underwriters Laboratories Inc.