

Certificate of Compliance

Certificate Number 20050617-E254077
Report Reference E254077, 2005 May 13
Issue Date 2005 June 17

Page 1 of 1



Issued to: **MEDC**
Colliery Rd, Pinxton
NG16 6JF Nottingham, United Kingdom


This is to certify that representative samples of **Heat-actuated Devices for use in Hazardous Location**
Class I, Division 2, Groups A, B, C, and D Hazardous Locations Heat-actuated device for special application, Type HD1

Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s) indicated on this Certificate.


Standard(s) for Safety: UL 1604 Electrical Equipment for Use in Class I and II, Division 2, and Class III Hazardous (Classified) Locations


Additional Information: Marking shall include Electrical ratings, company trade name or trademark, product identification, temperature rating in degrees fahrenheit, model number, date of manufacture and color code marking to verify temperature rating

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product

Issued by: 
Susan Kim, Staff Engineer
Underwriters Laboratories Inc.

Reviewed by: 
Paul Kelly / Operations Manager
Underwriters Laboratories Inc.